

Flammable and Combustible Liquid Storage Checklist

Requirements	EHB 15 Reference	YES	NO	N/A	Comments
Is initial and annual review of this procedure conducted and documented?	16.4.2				
Are flammable/combustible materials storage areas in compliance with requirements of this procedure?	16.3.1 16.5.2b				
Are storage cabinets available for storage of flammable/combustible liquids and are labeled "Flammable-Keep Fire Away"	16.3.1b(1)				
Are combustible waste materials (e.g., oily rags) stored in covered metal containers and removed from the work place promptly?	16.3.5c				
Are flammable/combustible liquid materials storage rooms provided with adequate ventilation to prevent accumulation of vapors?	16.3.2c				
Are adequate aisles provided and maintained to ensure unobstructed movement of personnel and access to the fire protection equipment?	16.3.5d				
Are all flammable liquids kept in closed containers when not in use?	16.3.1d(1)				
Are "NO SMOKING" signs posted in areas where flammable/combustible materials are used or stored?	16.3.1h				
Are spill kits available for cleanup of flammable/combustible materials spills?	16.3.2e				

Requirements	EHB 15 Reference	YES	NO	N/A	Comments
Are fire extinguishers available at the locations where flammable/combustible materials stored or used?	16.3.1i				
Are grounds around building and work areas in which flammable materials are stored or used kept free of trash, weeds or other combustible materials?	16.3.5e				